

Safety Department
 4200A N.W. 10th Avenue
 Oakland Park, FL 33309
 (754) 321-4200


**Comprehensive Safety Inspection
 State Requirements for Educational Facilities**

Fiscal Year: 2010-2011


Broward County School District - Charter Schools
 Somerset Academy Davie Loc. No: 5211
 3788 Davie Road
 Davie, FL 33314
 (954) 584-5528

Initial Inspection: Sep 20, 2010
 Re-Inspection #1: Apr 21, 2011

City of Davie Fire Rescue
 6901 Orange Drive
 Davie, FL 33314
 (954) 797-1229


 Thomas J. Keane #41712
 Municipal Firesafety Inspector

[x] Fire Safety [x] Casualty [x] Sanitation

Re-Inspection

 * Susan Dipuglia #75698
 Municipal Firesafety Inspector
 (Fire Violations only)

69A-58 No.	Sub Para.	Pri	Location		Type Def. M-O-C	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #	Re-Inspection			Inspector Completed Date	100% CD
			Bldg No.	Room No.								# 1 Status	#2 Status	#3 Status		
15	b6 03	B	0	9699			repair water fountain <i>drain clogged</i>			C				Sep 20, 2010		
13	p2 8	F	0	PLAYGRO			repair damaged equipment <i>repair bottom of fence north end east side</i>			C				Sep 20, 2010		
*	10	L d	B	1	000		install fish numbers <i>Identify all rms.by numbers,some painted over.</i>									
*	16	f1 07	B	1	000		install gfci within 6 ft water supply <i>All elect.recept.in sink proximity incl.109.</i>					C		Apr 21, 2011		
*	cs	01 10	B	1	102		Remove storage from restroom					C		Apr 21, 2011		
*	08	a 01	B	1	102		repair door (wood) <i>door sticks due to weatherstrip at bottom</i>			C				Sep 20, 2010		
*	cs	01 10	B	1	103		Remove storage from restroom									
	16	g 02	B	1	103		remove microwave/toaster from classroom <i>toaster oven in lounge</i>	1								
	cs	01 20	B	1	111		Repair unsafe/broken equipment <i>canopy over door coming loose</i>			C				Sep 20, 2010		
	01	02 01	B	1	112		Strap TV's to mobile cart <i>Strap/secure loose TV.</i>									
*	16	g 02	F	1	113		discontinue use of piggybacked surge strips									
	12	13 2	B	1	9599		Fill in washouts around sidewalks <i>Cement voids in the two paver walks at frt.of</i>									
	13	u1 6a	B	1	9698		Provide signage to read the following: <i>Post Indicator Valve</i>			C				Sep 20, 2010		
	02	c 6	B	1	9699		remove barbed wire within 6' of ground <i>& turn over barbs on rear chain link fence.</i>					C		Apr 21, 2011		
*	16	f1 13	B	1	KITCHEN		repair electrical outlet <i>Repair GFI Receptacles at sinks.</i>									

Safety Department
 4200A N.W. 10th Avenue
 Oakland Park, FL 33309
 (754) 321-4200

**Comprehensive Safety Inspection
 State Requirements for Educational Facilities**

Initial Inspection: Sep 20, 2010
 Re-Inspection #1: Apr 21, 2011

City of Davie Fire Rescue
 6901 Orange Drive
 Davie, FL 33314
 (954) 797-1229

Fiscal Year: 2010-2011

Broward County School District - Charter Schools
 Somerset Academy Davie Loc. No: 5211
 3788 Davie Road
 Davie, FL 33314
 (954) 584-5528

Fire Safety Casualty Sanitation

69A-58 No.	Pri Sub Para.	Location		Type Def. M-O-C	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #	Re-Inspection			Inspector Completed Date	100% CD
		Bldg No.	Room No.								# 1 Status	# 2 Status	# 3 Status		


Total Non-Fire Safety Deficiencies 3

Total Fire Safety Deficiencies(*) 4 (Includes 0 Serious Life Safety Deficiencies**)

Total Deficiencies Cited: 7

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY:

Ten Fire Exit Drills during the School Year Yes [] No (NFPA 101)



4-27-11

Signature of Facility Administrator attesting to fire exit drills and review of Re-inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F. S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.